



April 22, 2016

Lt. Jason Chappell  
Kirkland Fire Department  
123 5<sup>th</sup> Avenue  
Kirkland, WA 98033

Dear Lt. Chappell,

This resubmittal for the Kirkland Parkplace Building D project includes modifications to the original submittal as detailed below:

- Hydraulic Calculations have been printed using NFPA reporting format.
- Penthouse drawing has been modified to reflect replacement of sprinkler heads with quick response sprinklers.
- Hydraulic Calculations for the penthouse have been redone using NFPA-13 area reduction for quick response sprinklers.

Please find new “Sprinkler Plan FP-L5, LPent” drawing dated 4.22.16.

Please find new Hydraulic Calculations for both the office and penthouse areas.

Other drawings and submitted materials have not changed.

Please contact me with any questions.

Sincerely,

Cameron L Smith, PE

McKinstry Company  
5005 3<sup>rd</sup> Ave S  
Seattle, WA 98134  
206-832-8748